

Certificate of Conformity

Certification No. : 18-34-090

Company Name : DK-LOK Corporation

Address : 7. Golden root-ro 129 beon-gil, Juchon-myeon,
Gimhae-si, Gyeongsangnam-do, South Korea



President : Eun-Sik, No

Item : Valve for Piping(27.4 MPa, Ball Valve)

Type(Model) : VC8D-F-16N-PK

Service Gas : LPG, NG

A term of validity : April. 9. 2018 ~ April. 8. 2023

Inspector : Hun, Kang  Technical manager : Yun-Won, Choi 

This is to certify that the above item passed the type test in Article 17 of High Pressure Gas Safety Control Act or Article 39 of Liquefied Petroleum Gas Safety Control & Business Act.

Date Certified April. 9. 2018.

Korea Gas Safety Corporation

1390, Wonjung-ro, Maengdong-myeon, Eumseong-gun, Chungcheongbuk-do, Korea

Tel : +82 43 750 1512 Fax : +82 43 750 1930



Test Report

Certification No. : 18-34-090
Method of Inspection : KGS AA331 : 2017
Item : Valve for Piping(27.4 MPa, Ball Valve)
Model : VC86D-F-16N-PK
Manufacturing Nation/Company : KOREA / DK-LOK Corporation
Service Gas : LPG, NG
Working Pressure : 27.4MPa
Material of Body : ASTM A479 316
Material of Cover : ASTM A276 316
Material of Ball : ASTM A276 316
Material of Seat : PEEK
Size : 25A(1")
End-to-End Dimension : (112.9± 0.5) mm
Valve Operating Type : Lever
End Connection Type(Inlet) : NPT
End Connection Type(Outlet) : NPT
Assembling of Body and Cover-1 : 3-piece
Assembling of Body and Cover-2 : Screw Thread
Construction-1 : Full Bore
Construction-2 : Floating Type

-End of Information-

Korea Gas Safety Corporation

1390, Wonjung-ro, Maengdong-myeon, Eumseong-gun, Chungcheongbuk-do, Korea

Tel : +82 43 750 1512 Fax : +82 43 750 1930